

305 Overhead High Potential Electrical Circuits

- (1) **Definition.** Any electrical circuit which is or may be energized at a potential in excess of 15,000 volts between any two conductors shall be considered as a high potential electrical circuit.
- (2) **Requirements.** No high potential electrical circuit shall be constructed or maintained in or with the City unless it is installed in a subway or underground conduit system which meets the requirements of the National Electrical Safety Code and/or such other criteria as the City Council may prescribe.